





Adres:

SZYDŁOWIEC, UL. KOLEJOWA

Wyniki doboru grzejników:

Pomieszczenie	Q	Dobrany grzejnik	L	H	G	Numer katalogowy
	W		[m]	[m]	[m]	
PARTER						
1.1/POM. BIUROWE	1222	CV22-60	1,20	0,60	0,10	
1.2/POM. BIUROWE	924	CV22-60	0,90	0,60	0,10	
1.3/WIATROŁAP	234	CV11-60	0,40	0,60	0,06	
1.4/KOMUNIKACJA	1206	CV22-60	1,20	0,60	0,10	
1.5/WC	847	CV22-60	1,20	0,60	0,10	
PIĘTRO						
2.1/POM. BIUROWE	1417	CV22-60	1,40	0,60	0,10	
2.2/POM. BIUROWE	1194	CV22-60	1,20	0,60	0,10	
2.3/WC	684	CV22-60	0,90	0,60	0,10	
2.4/KOMUNIKACJA	1288	CV22-60	1,40	0,60	0,10	

Zestawienie materiałów:

Typ	Symbol	L	H	Numer katalogowy	Ilość	Producent
		[m]	m		[szt.]	
	CV11-60	0,40	0,600		1	
	CV22-60	0,90	0,600		2	
	CV22-60	1,20	0,600		4	
	CV22-60	1,40	0,600		2	